

# BOYCE HYDRO POWER, LLC

*A W.D. Boyce Trusts Legacy Enterprise*  
*Stephen B. Hultberg & Lee W. Mueller, Co-Member Managers*  
6000 S. M-30 (P.O.Box 15)  
Edenville, MI 48624  
tel: (989) 689-3161 / (989) 689-0895



February 14, 2013

Mr. John Zyga, PE  
Regional Engineer  
Federal Energy Regulatory Commission  
230 S. Dearborn St., Suite 3130  
Chicago, IL 60604

Re: Edenville P-2785  
2012 CSIR Recommendations

Dear Mr. Zyga:

We are writing to respond to the recommendations contained the 2012 Sanford CSIR. We accept the recommendations as written and propose to accomplish them as scheduled below. There were ten recommendations in the Report and we will address them in the order they were presented in the CSIR.

1. Removal of the woody growth on the fuse plug is done on an annual basis.
2. Reading the observation wells is done as part of the monthly dam inspections.
3. Mowing the embankments is done on a regular basis during the summer months.
4. We plan to raise the top of embankment elevation on or before 2017.
5. Our concrete repair program is scheduled as follows:
  - Left tailrace retaining wall reconstruction in 2013
  - Powerhouse concrete repairs and upwelling in 2014
  - Rehab north retaining wall, spillway toe wall, spillway piers, training wall in 2015
6. Covered in item 5
7. Removal of grass and growth from gates and spillways will be done annually
8. Repaint steel and walkway on spillways in 2016
9. Touch up paint on gates in 2016
10. Covered in item 5

Plans and specifications for the work proposed for 2013 have already been submitted to the FERC. Plans and specifications for the work proposed in 2014 will be submitted in the latter part of 2013.

Sincerely,

  
Frank O. Christie, PE  
General Manager

cc: L. Mueller, S. Hultberg, S. Doret

Document Content(s)

13196078.tif.....1-1