

FEDERAL ENERGY REGULATORY COMMISSION
Office of Energy Projects
Division of Dam Safety and Inspections - Chicago Regional Office
230 South Dearborn Street, Suite 3130
Chicago, Illinois 60604
(312) 596-4430 Office - (312) 596-4460 Facsimile

In reply refer to: Project No. 2785

August 12, 2013

Mr. Lee Mueller
Boyce Hydro Power, LLC
4132 Rainbow Rd #247
Las Vegas, Nevada 89103

Re: 2012 CSIR Recommendations
Sanford Hydroelectric Project (P-2785)

Dear: Mr. Mueller:

We have completed our review of the February 14, 2013 submittal regarding your plan and schedule for implementing the 2012 Consultant's Safety Inspection Report (CSIR) recommendations for your Sanford Hydroelectric Project (P-2785). Your plan and schedule is satisfactory. The following recommendations should be completed by the dates indicated.

1. The top of the embankment should be raised by **November 15, 2017**.
2. The left tailrace retaining wall should be reconstructed by **November 15, 2013**.
3. The powerhouse concrete repairs and upwelling should be completed by **November 15, 2014**.
4. The remaining concrete repairs should be completed by **November 15, 2015**.
5. Repainting of the steel members, walkway, and gate touch ups should be completed by **November 15, 2016**.

If there are any questions regarding the report requirements, please call Mr. Peter Chapman at 312-596-4446 or me at 312-596-4430.

Sincerely,

A handwritten signature in black ink, appearing to read "John A. Zygaj". The signature is written in a cursive style with a large, sweeping "Z" and "y".

John A. Zygaj, P.E.
Regional Engineer

cc: Mr. Frank Christie, General Manager
Boyce Hydro Power, LLC
6000 S. M-30, P.O. Box 15
Edenville, MI 48620

Document Content(s)

13338728.tif.....1-2