

**FEDERAL ENERGY REGULATORY COMMISSION**  
**Office of Energy Projects**  
**Division of Dam Safety and Inspections - Chicago Regional Office**  
**230 South Dearborn Street, Suite 3130**  
**Chicago, Illinois 60604**  
**(312) 596-4430 Office - (312) 596-4460 Facsimile**

In reply, refer to: P-2785, P-10808,  
P-10809, and P-10810

October 7, 2015

Mr. Lee Mueller  
Boyce Hydro Power, LLC  
10120 W. Flamingo Road, Suite #4-192  
Las Vegas, Nevada 89147

**Re: Gate Opening Verification**  
**Sanford Hydroelectric Project – FERC No. 2785**  
**Edenville Hydroelectric Project – FERC No. 10808**  
**Secord Hydroelectric Project – FERC No. 10809**  
**Smallwood Hydroelectric Project – FERC No. 10810**

Dear Mr. Mueller:

We have reviewed your August 31, 2015 letter indicating the maximum gate open elevations at your Sanford (P-2785), Secord (P-10809), Smallwood (P-10810), and Edenville (P-10808) Hydroelectric Projects. The letter indicates the gates along the powerhouses at your Smallwood, Edenville, and Sanford projects cannot be opened 11 feet as originally anticipated. You should verify the rating curve for each project matches the gate openings identified in your letter. Rating curves should be updated if they do not match.

A letter verifying the rating curves and any updated rating curves should be submitted by **December 31, 2015**. Please contact Peter Chapman, P.E. at (312) 596-4446 or me at (312) 596-4430 if you have questions concerning this letter.

Sincerely,

John A. Zygaj, P.E.  
Regional Engineer

CC: Mr. Frank Christie, P.E., General Manager  
Boyce Hydro Power, LLC  
P.O. Box 15  
Edenville, MI 48620

Document Content(s)

02785\_10808\_10809)10810\_Gate opening verification\_34203.PDF.....1-1