

FEDERAL ENERGY REGULATORY COMMISSION
Office of Energy Projects
Division of Dam Safety and Inspections
Chicago Regional Office
230 South Dearborn Street, Suite 3130
Chicago, Illinois 60604
(312) 596-4430 Office - (312) 596-4460 Facsimile

In reply refer to: P-10808

September 26, 2018

Mr. Lee Mueller
Boyce Hydro Power, LLC
10120 West Flamingo Road, Suite #4-192
Las Vegas, Nevada 89103

Re: Disabling Generating Equipment
Edenville Hydroelectric Project (FERC No. 10808)

Dear Mr. Mueller:

We have completed our review of your September 24, 2018 filing detailing the disconnection of generation equipment at your Edenville Hydroelectric Project (P-10808). Your plan is to remove two breakers and pull the high voltage knife switches. Your plan is acceptable. It is suggested that you have your electrical provider install a proper electrical service to your powerhouse so you have adequate supply of electricity to your powerhouse, offices, shop, and garage buildings.

You may contact me at 312.596.4430 or Mr. Peter Chapman at 312.596.4446 if you have any questions.

Sincerely,

for John Zygaj, P.E.
Regional Engineer